

Outfall 001

Date	Flow MGD 30 Day Avg	TSS			pH		Oil/Grease	TDS	TDS	Iron
		25 mg/L 30 Day Avg	35 mg/L 7 Day Avg	70 mg/L Daily Max	6.5 SU Daily Min	9 SU Daily Max	10 mg/L Daily Max	1200 mg/L Daily Max	350 tons Annual tot.	1 mg/L Daily Max
3/31/06	0.4392	5	5	5	6.83	7.14	No sheen	750	124	0.05
6/30/06	0.2872	7	7	7	6.9	7.25	No sheen	731	202	0.05
9/30/06	0.4614	5	5	5	69.2	72.9	No sheen	715	326	0.07
12/31/06	0.3354	5	5	5	7.1	7.4	No sheen	765	423	0.1
3/31/07	0.3343	8	8	8	6.86	7.6	No sheen	743	93	0.07
6/30/07	0.5496				7.1	8.1	No sheen	766	251	0.07
9/30/07	0.1789	5	5	5	6.3	7.1	No sheen	751	302	0.03
12/31/07	0.1156	0.5	0.5	0.5	6.8	7.4	No sheen	755	334	0.1
3/31/08	0.3989	7	7	7	7.3	7.5	No sheen	765	115	0.1
6/30/08	0.3613	0.5	0.5	0.5	7	7.6	0.2	756.33	217	0.07
9/30/08	0.1319	5	5	5	7.35	7.35	No sheen	764	255	0.05
12/31/08	0.1374	5	5	5	7.4	7.08	No sheen	770	295	0.05

Outfall 002

Date	Flow MGD 30 Day Avg	TSS			pH		Oil/Grease	TDS	TDS	Iron
		25 mg/L 30 Day Avg	35 mg/L 7 Day Avg	70 mg/L Daily Max	6.5 SU Daily Min	9 SU Daily Max	10 mg/L Daily Max	1200 mg/L Daily Max	350 tons Annual tot.	1 mg/L Daily Max
3/31/06	0.0792	5	5	5	4.97	7.27	No sheen	752	22	0.05
6/30/06	0.0672	5	5	5	7.1	7.76	No sheen	729	41	0.05
9/30/06	0.0552	5	5	5	6.9	7.14	No sheen	709	55	0.06
12/31/06	0.084	5	5	5	7.1	7.3	No sheen	740	79	0.05
3/31/07	0.0768	5	5	5	7	7.9	No sheen	748	22	0.08
6/30/07	0.2472				7.4	7.4	No sheen			
9/30/07	0.223	5	5	5	7.3	7.4	No sheen	744	167	0.03
12/31/07	0.444	0.5	0.5	0.5	6.3	7.3	No sheen	750	292	0.09
3/31/08	0.1032	18	18	18	7.3	7.5	2	767	30	0.11
6/30/08	0.155	5	5	5	7.5	7.6	2	759.67	74	0.2
9/30/08	0.0672	134	134	134	7.65	7.65	No sheen	753	93	0.3
12/31/08	0.087	5	5	5	7.7	7.82	No sheen	769	130	0.05

Outfalls 003-013 did not discharge during this time frame.
 DMR submitted for second quarter 2007 was incomplete.
 Facility has not submitted any DMRs in 2009.

Bold indicates an effluent violation.